

### CLIENT AND LOCATION DETAILS

Mr S Chidgey  
The Old Barn  
Tregonetha  
TR9 6EL

The Old Barn

### TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
001	Wine cooler	08/08/2018	2	230	Pass		>99.90	0.00						Pass
002	Aga	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
003	coffee machine	08/08/2018	2	230	Pass		>99.90	0.66						Pass
004	Kettle	08/08/2018	1	230	Pass	0.09	>99.90	2.63	0.10					Pass
005	Coffee warmer	08/08/2018	2	230	Pass		>99.90	0.00						Pass
006	Microwave	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
007	Food mixer	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
008	Dishwasher	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
009	Fridge	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
010	Washing machine	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
011	Tumble dryer	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
012	Wine cooler	08/08/2018	1	230	Pass	0.02	>99.90	0.00	<0.10					Pass
013	Iron	08/08/2018	1	230	Pass	0.06	>99.90	0.00	<0.10					Pass
014	Hoover	08/08/2018	2	230	Pass		>99.90	0.00						Pass
015	Table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
016	Table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
017	Table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
018	Alarm clock	08/08/2018	2	230	Pass		>99.90	0.00						Pass
019	torches	08/08/2018	2	230	Pass		>99.90	0.00						Pass
020	Torch	08/08/2018	2	230	Pass		>99.90	0.00						Pass
021	Table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
022	TV	08/08/2018	2	230	Pass		>99.90	0.00						Pass
023	Dvd player	08/08/2018	2	230	Pass		>99.90	0.00						Pass
024	BT router	08/08/2018	2	230	Pass		>99.90	0.00						Pass
025	Table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
026	table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
027	Table lamp	08/08/2018	2	230	Pass		>99.90	0.00						Pass
028	torch	08/08/2018	2	230	Pass		>99.90	0.00						Pass

### CONTRACTOR DETAILS

Davey Electrical Services Ltd  
Unit 4a Bess Park Road  
Trenant Industrial Estate  
Wadebridge  
Cornwall PL27 6HB

Tester Name Christopher Davey  
Qualifications Electrician  
Position

Signature